

## Register of Portable Appliance Tests

**Carried out for:**

RPC Limited, 62 High Street, Horsham, Surrey. RH34 3EW

**Test Dates:**

18th - 19th April 2004

**Re-test Due:**

April 2005

Testing carried out by: -

### Brighton PAT Testing



9 Bembridge Street, Brighton, East Sussex. BN2 3LN  
T: 0800 860 0428 - [info@brightonpattesting.co.uk](mailto:info@brightonpattesting.co.uk)  
[www.brightonpattesting.co.uk](http://www.brightonpattesting.co.uk)

Number of Assets: 499  
Number Passed: 496  
Number Failed: 3

Appliances Re-Terminated: 7  
Plugs Replaced: 6  
Fuses Replaced: 19

PAT Equipment: Megger PAT4DV - 9008066  
Calibrated 23/03/2004  
Calibration Certificate No. C09413

Engineer: J Clelland

Signed:

